

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 7165-0992:121

Page 1 of 1

**CATEGORY:** Control Unit (Non High-Rise)

**LISTEE:** Napco, 333 Bayview Avenue, Amityville, NY 11701  
Contact: \*Edmund Gregorian (631) 842-9400 Fax (631) 842-2726

**DESIGN:** Model FW-C2Z, FW-C4Z and FW-C4EZ fire alarm control units. Non-coded; automatic, manual, local, remote station, central station, waterflow and sprinkler supervisory service. System components:

FW-C2Z, -C4Z, -C4EZ	Main Fire Alarm Assembly
FW-EZM4	Initiating & NAC Zones
FW-RB4, FW-RB8	Relay Module
FW-RPM	Polarity Reversal & City Tie
FW-DACT	DACT
BB-815, BB-816	Enclosure

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to listee's Installation instructions Manual for details.

This control unit meets the requirements of UL-864, 8<sup>th</sup> Edition Standard.

**NOTE:** For **Fire Alarm Verification Feature**, the maximum Retard/Reset/Restart period shall not exceed 30.0 seconds.

**XLF:** 7165-1477:109

\*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 22, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*

